



Town of Holderness
 PO Box 203, Route 3
 Holderness, NH 03245-0203
 Phone: (603) 968-2145
 Fax: (603) 968-9954

TOWN OF HOLDERNESS
DISTANCES IN FEET FOR SEWAGE DISPOSAL SYSTEMS

| | <u>Septic Tank</u> | <u>Leach Field</u> | <u>Dry Well</u> | <u>Sewer Line</u> |
|---|------------------------|------------------------|---------------------|-----------------------|
| Surface water | 75 | 125 | 75 | |
| Open Drainage | 75 | 75 | 75 | |
| Culvert (tight pipe) | 25 | 35 | 35 | |
| Culvert opening | 50 | 75 | 75 | |
| Catch basin | 35 | 35 | 35 | |
| In-around swimming pool | 25 | 35 | 50 | 10 |
| Private well, on-site | 75 | 125 | 75 | |
| Private well, off-site | 75 | 125 | 75 | |
| Community well | 200 | 200 | 200 | |
| Reservoirs | 75 | 75 | 75 | |
| Municipal well | 400 | 400 | 400 | 400 |
| Water line, pressure | 10 | 25 | 25 | 10 |
| Water line, suction | 50 | 75 | 75 | 50 |
| Property line | 35 | 35 | 35 | 35 |
| Foundations: | | | | |
| With drains | 25 | 35 | 35 | |
| Full (no drains) | 5 | 10 | 10 | |
| Slab (no drains, | 5 | 5 | 5 | |
| Top of natural embankment or natural steep slope | 5 | 20 | 20 | |
| Interceptor drains, leaching area | | | | |
| Below finished grade | 50 | 75 | 75 | 75 |
| Above finished grade | 35 | 35 | 35 | 35 |